CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0694:250 Page 1 of 1

CATEGORY: Control Unit (Non High Rise)

LISTEE: Fire Control Instruments, *16 Southwest Park, Westwood MA 02090

Contact: Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

DESIGN: Models FC-73 Fire Alarm Control Unit Power limited, automatic, manual, local, auxiliary,

remote, central, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System

components:

FC-73/O52090C.1 Main Board FC-73CB Enclosure

FC-5280 Status Display Module LCD-FC73 Remote Annunciator ZDM-FC73 Zone Expander.

RATING: 120 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes &

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed electrically and functionally

compatible initiating and indicating devices.

This control unit does not generate a temporal code pattern fire alarm signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total

evacuation) in accordance with NPFA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's

Installation Manual for details.

NOTE: For <u>Fire Alarm Verification Feature</u> (delay of alarm signaling), the Retard/Reset/Restart

period shall be 30 seconds or less.

*Rev. 02-05-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: FEBRUARY 5, 2004 Listing Expires June 30, 2004

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager